



**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

YMCA of Vineland  
1159 East Landis Avenue  
Vineland, NJ 08360  
856-691-0030 x 106

www.sjwatertest.com  
NJ DEP Certified Lab # 08006

Sample Location: Girls Bathroom

Date Sampled: 07/03/24

Time Sampled: 05:15

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
<b>Sample ID:</b>	<b>W140018</b>					
Lead	9-JUL-2024 11:53	<2.00	ug/L	2.0	15.5	SM3113B
Copper	8-JUL-2024 13:26	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Boys Bathroom

Date Sampled: 07/03/24

Time Sampled: 05:12

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
<b>Sample ID:</b>	<b>W140019</b>					
Lead	9-JUL-2024 12:13	<2.00	ug/L	2.0	15.5	SM3113B
Copper	8-JUL-2024 13:27	<0.050	mg/L	0.05	1.3	SM3111B

Sample Location: Kitchen

Date Sampled: 07/03/24

Time Sampled: 05:00

Test/ Parameter	Date/Time Analyzed	Result	Units	Reporting Limit	Allowable Limit	Method
<b>Sample ID:</b>	<b>W140020</b>					
Lead	9-JUL-2024 12:19	11.38	ug/L	2.0	15.5	SM3113B
Copper	8-JUL-2024 13:27	0.054	mg/L	0.05	1.3	SM3111B

This report relates only to the samples as received by the laboratory.

Mark J. Riether, Lab Director

07/10/2024

Date

**CHAIN OF CUSTODY RECORD**

<b>Customer:</b>	YMCA of Vineland
<b>Contact:</b>	Gene Fleming
<b>Address:</b>	1159 East Landis Avenue Vineland, NJ 08360
<b>Phone:</b>	856-691-0030 x 106
<b>Office:</b>	Fax:

**South Jersey Water Test, LLC**  
 4077 South Black Horse Pike  
 Williamstown, NJ 08094  
 Phone: 856-875-3506 Fax: 856-875-3507  
 www.sjwatertest.com  
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
	Field Reagent Blank <i>KB</i>	7-3-24	5:00		D	1 x 250	HNO3*	First Draw Lead and Copper	
W140018	<i>Girls bathroom</i>	7-3-24	5:15		D	1 x 250	HNO3*	First Draw Lead and Copper	
W140019	<i>boys bathroom</i>	7-3-24	5:12		D	1 x 250	HNO3*	First Draw Lead and Copper	
W140020	<i>Al's kitchen</i>	7-3-24	5:00		D	1 x 250	HNO3*	First Draw Lead and Copper	
					D	1 x 250	HNO3*	First Draw Lead and Copper	
					D	1 x 250	HNO3*	First Draw Lead and Copper	
					D	1 x 250	HNO3*	First Draw Lead and Copper	
					D	1 x 250	HNO3*	First Draw Lead and Copper	
					D	1 x 250	HNO3*	First Draw Lead and Copper	
					D	1 x 250	HNO3*	First Draw Lead and Copper	

MATRIX ABBREVIATIONS: D\DRINKING WATER A\AQUEOUS S\SOIL SL\SLUDGE GW\GROUND WATER SW\SURFACE WATER WW\WASTE WATER

<b>Turnaround Time</b>	Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	<b>Report Format</b>	<b>Comments/Special Instructions</b>	<b>Cooler Temp</b>
<input type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____			* HNO3 preserved upon receipt at laboratory	°C
				Yes No

<b>Sampled by:</b> (Print) <i>Richard Cook</i>	<b>Date</b> 7-3-24	<b>Time</b> 3:30	<b>Received by:</b> (Signature) <i>[Signature]</i>	<b>Date</b> 7/3/24	<b>Time</b> 1430
<b>Sampled by/Relinquished by:</b> (Signature) <i>[Signature]</i>	<b>Date</b>	<b>Time</b>	<b>Received by:</b> (Signature)	<b>Date</b>	<b>Time</b>
<b>Relinquished by:</b> (Signature)	<b>Date</b>	<b>Time</b>	<b>Received by:</b> (Signature)	<b>Date</b>	<b>Time</b>
<b>Relinquished by:</b> (Signature)	<b>Date</b>	<b>Time</b>	<b>Received by:</b> (Signature)	<b>Date</b>	<b>Time</b>